

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
L.M. Dey Garden, D.H. Road, Silpara, Pin - 700008**

Memo No : IND/WB/FES/20222023/81920

DATE: 19/01/2024

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :

Shri Santoshi Maa Academy
Kalagachia, Khalpar,
Thakhrpukur, Maheshtala,
South 24 Paganas,
Kolkata - 700063.

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + III storied building under group Educational at the premises no.- 176/M, Opposite Joka Metro Car Shed, Thakurpukur, P.S.- Maheshtala, Dist. - South 24 pgs, Pin.- 700063.

This is in reference to your Application No. IND/WB/FES/20222023/81920, dated 19/01/2023, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + III storied building under group Educational at the premises no.- 176/M, Opposite Joka Metro Car Shed, Thakurpukur, P.S.- Maheshtala, Dist. - South 24 pgs, Pin.- 700063.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1.Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
- 2.The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.

- 3.To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 4.Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
- 5.The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
- 6.The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
- 7.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8.Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.
- 9.First aid Fire fighting system shall be provided as per I.S. specification.
- 10.Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
- 11.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
- 12.Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
- 13.This F.S.C. is valid for 03(Three) years from the date of issue of this letter.
- 14.R.F.S.C is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by DIPAK
KUMAR GHOSH
Date: 2023.01.19 16:31:21 IST